

Inspection of Shipment for Suspected Asbestos Containing Container House QM3379113

825 Lorimer Street, Port Melbourne

Flight/voyage:	9238789
Owner:	ER Painting Services Pty Ltd
Supplier:	Xiamen Umd Industrial Co. Ltd
PCI Group:	RedlineWA
ABN/CCID:	23636738040
Broker:	Compliant Customs Pty Ltd
FID:	AE99FPYY7
Depot:	Lawson Sideloader Services Pty Ltd
OBL/MAWB:	MEDUJG608550
Container No.:	FCIU8555561

On 23 December 2024, a representative of Alpha Environmental Pty Ltd (Alpha) inspected a shipment of a container house, as described in QM3379113 (the Shipment), located at 825 Lorimer Street, Port Melbourne. Refer to **Figure 1** attached which illustrates the items in the Shipment.

During the inspection, Alpha collected two representative samples of suspected asbestos-containing (AC) materials from the Shipment for laboratory analysis.

The samples were placed into individual snap lock bags, labelled with unique sample numbers, and forwarded to the Alpha laboratory (NATA accreditation number 19066) for qualitative analysis of bulk samples by polarised light microscopy in conjunction with dispersion staining.

The results of the analysis are as follows:

- AE2412047-A: Vinyl floor covering – **No asbestos detected**; and
- AE2412047-B: Fibro – **No asbestos detected**.

A copy of the Alpha certificate of analysis **AL2412044-001** is attached.

Refer to **Figure 2** attached which illustrates the materials sampled by Alpha.

At the completion of the inspection, Alpha was satisfied that the Shipment was free of AC material.

Please call me on 9415 8002 if you have any questions.

Regards,

e-signature


Darren Huett

Senior Occupational Hygienist

Alpha Environmental Pty Ltd

(NATA Accredited, VTHC Approved and ACLCA Members)

Attached: Alpha certificate of analysis AL2412044-001



Figure 1: The Shipment



Figure 2: Vinyl floor covering/fibro cement sheet

Certificate of Analysis - Asbestos Identification

Laboratory Report No: AL2412044-001
Attention: Alpha Environmental Pty Ltd
Angelo Papanikolas
205/134 Cambridge St
COLLINGWOOD VIC 3066

Client Reference: AE2412047

Sample Date: 23 December 2024

Sample Received Date: 30 December 2024

Analysis Date: 30 December 2024

Report Issue Date: 30 December 2024

Site Location: Lawson Sideloader Services Pty Ltd, 825 Lorimer Street PORT MELBOURNE 3207

Methodology: Samples analysed by Polarised Light Microscopy, including Dispersion Staining as received by Alpha Environmental, in accordance with Alpha Environmental Procedure Manual, Method LAB46, with reference to AS4964-2004 *Method for the Qualitative Identification of Asbestos in Bulk Samples*.

Report Comments:

Signatories:



Celeste Tong
Approved Identifier

Certificate of Analysis - Asbestos Identification

Laboratory Report No: AL2412044-001
Client Reference: AE2412047
Site Location: Lawson Sideload Services Pty Ltd, 825 Lorimer Street PORT MELBOURNE 3207

Analytical Results

Sample ID	Location	Sample Description	Sample Mass (g)	Fibres Present	Note
001	AE2412047-A: Vinyl Sheet	Grey-white Vinyl Sheet	0.9	No Asbestos Detected	
002	AE2412047-B: Fibro	Fibre Cement Fragment	0.9	No Asbestos Detected Synthetic Mineral Fibres Detected	